



- WET WELL AND PEDESTRIAN RATED COVER NOT DESIGNED FOR TRAFFIC LOADING.
- ONSITE PROVISIONS (SUCH AS BARRICADING) MAY BE REQUIRED TO ENSURE THAT WET WELL AND/OR COVER ARE NOT SUBJECT TO TRAFFIC LOADING.

SITE SPECIFICATION SHEET

**XERXES**<sup>®</sup>  
CORPORATION

TITLE FIBERGLASS WET WELL  
FLAT TOP AT GRADE  
INSTALLATION, NON-TRAFFIC

DATE 1-10 DR. NO. S20-744.00