



300# PEDESTRIAN RATED
ACCESS COVER

DISCHARGE PIPE

12" MIN.

12" MIN.

GEOTEXTILE
FABRIC

BACKFILL TO BOTTOM OF
DISCHARGE PIPING

BACKFILL
TO GRADE

GEOTEXTILE
FABRIC

MINIMUM METHOD

TYPICAL METHOD

- WET WELL AND PEDESTRIAN RATED COVER NOT DESIGNED FOR TRAFFIC LOADING.
- ONSITE PROVISIONS (SUCH AS BARRICADING) MAY BE REQUIRED TO ENSURE THAT WET WELL AND/OR COVER ARE NOT SUBJECT TO TRAFFIC LOADING.

SITE SPECIFICATION SHEET

XERXES[®]
CORPORATION

TITLE FIBERGLASS WET WELL
OPEN TOP AT GRADE
INSTALLATION, NON-TRAFFIC

DATE 1-10

DR. NO. S20-738.00